



Bourke Shire Council

Bourke Treatment Plant

Licence 11570

Test Results

January 2021

December 2021

Calculation of Pollutant Loads for EPA Annual Reporting in accordance with DECC Load Calculation Protocol 2008

Return calculation for period from JAN 2021 to DEC 2021

Concentration: C_d (mg/L)

EPL	MONITORING LIMITS							
11570	MG/L	15	15	10	10	20	6.5-8.5	100 ug/l
Test	Date Taken	BOD	Nitrogen (total)	Oil and Grease	Phosphorus (total)	TSS	pH	Chlorophyll a

Table 1 -- Test Results (mg/L)

PQL		2	0.3	5	0.02	3		
1	13.01.2021	12	10.3	4	1.3	36	9.38	238
2	.02.2021							
3	.03.2021							
4	.04.2021							
5	.05.2021							
6	.06.2021							
7	.07.2021							
8	.08.2021							
9	.09.2021							
10	.10.2021							
11	.11.2021							
12	.12.2021							